



<b>SIL-DECLARATION of CONFORMITY</b> <i>SIL-DICHIARAZIONE DI CONFORMITA'</i>	<b>EN 50402 ; EN 61508</b>
---	----------------------------

N.E.T. S.r.l. – 20010 Cornaredo (MI) ITALY Via Legnano, 2, hereby declares under its own responsibility that the gas detection units

**Model Cyber++ EC – Electrochemical Cell 4-20mA gas sensing transmitter**

comply with the following European / International Standards for Functional Safety:

**EN 50402:2005 + A1:2008 ; EN/IEC 61508:2010 parts 1 to 7**

The Functional Safety Assessment was carried out by GWW GasWarn Dr. Wenker GmbH in cooperation with of N.E.T. S.r.l. see the enclosed Compliance Statement CST2711 of GWW dated May 13<sup>th</sup> 2011. The results are given in the Report FSR2737 by GWW GasWarn Dr. Wenker GmbH (Dortmund / Germany) as independent consultant for SIL specifying the following data for the use of single channel (1 out of 1) or redundant (1 out of 2) sensors. To achieve the claimed SIL-compliance for the sensors the conditions for use overleaf have to be obeyed.

	<b>Single sensor 1oo1</b>	<b>Redundant sensors 1oo2</b>
Safety function	4-20mA output equivalent to measured gas concentration	
Measuring range	0 – 25(30) %Vol. for oxygen and 0 – 300(500) ppm for CO	
SIL Capability Hardware	2	3
SIL Capability Software	2	2
Type of device	B	
Proof test interval	1 year	
MTTR	24 h	
SFF	93,62 %	
HFT	0	1
β Factor	—	10 %
PFD	$5,07 \times 10^{-4}$	$5,10 \times 10^{-5}$
$\lambda_{du}$	$1,13 \times 10^{-7}$ (per h)	
$\lambda_{dd}$	$2,94 \times 10^{-7}$ (per h)	
$\lambda_{su}$	$1,37 \times 10^{-6}$ (per h)	
$\lambda_{sd}$	0 (per h)	

Cornaredo Date: May 13<sup>th</sup> 2011

Dott. Giacomo Frigo  
(General Director / Amministratore Unico)



**Nano Environmental Technology**  
**The Reliable Alternative**



## Conditions for use

The values for the SIL-Capability of the CYBER EC transmitter and the determined failure rates are valid only if the following conditions for use will be obeyed (responsibility of the user).

The detector has to be placed at a position suitable for the measuring application, to be connected correctly to the central unit and to be put into operation by the detector manufacturer or an authorized installer company.

Output signals of the transmitter of < 2 mA (fail low) and > 22 mA (fail high) have to be recognized by the central unit as transmitter failure.

The environmental parameters (e.g. the ranges for temperature, humidity and pressure) specified in the users manual have to be observed and followed.

The transmitter has to be maintained regularly following the instructions of N.E.T. and to be calibrated using a certified calibration gas mixture.

The proof test has to be carried out once per year. As proof test a regular calibration has to be carried out without additional requirements.